

APA-1
07/04

**TRANSMITTAL SHEET FOR
NOTICE OF INTENDED ACTION**

Control No. 309 Department or Agency Plumbers & Gas Fitters Examining Board
Rule No. 720-x-2-.02
Rule Title: On-site Wastewater
 New Amend Repeal Adopt by Reference

Would the absence of the proposed rule significantly harm or endanger the public health, welfare, or safety? Yes

Is there a reasonable relationship between the state's police power and the protection of the public health, safety, or welfare? No

Is there another, less restrictive method of regulation available that could adequately protect the public? No

Does the proposed rule have the effect of directly or indirectly increasing the costs of any goods or services involved and, if so, to what degree? No

Is the increase in cost, if any, more harmful to the public than the harm that might result from the absence of the proposed rule? No


Are all facets of the rulemaking process designed solely for the purpose of, and so they have, as their primary effect, the protection of the public? Yes

Does the proposed rule have an economic impact? No

If the proposed rule has an economic impact, the proposed rule is required to be accompanied by a fiscal note prepared in accordance with subsection (f) of Section 41-22-23, Code of Alabama 1975.

Certification of Authorized Official

I certify that the attached proposed rule has been proposed in full compliance with the requirements of Chapter 22, Title 41, Code of Alabama 1975, and that it conforms to all applicable filing requirements of the Administrative Procedure Division of the Legislative Reference Service.

Signature of certifying officer 

Date 11/30/2015

(DATE FILED)
(STAMP)

APA-2
07/04

**State of Alabama Plumbers & Gas Fitters
Examining Board**

NOTICE OF INTENDED ACTION

AGENCY NAME:

Alabama Plumbers and Gas Fitters Examining Board

RULE NO. & TITLE:

720-x-2.02 On-site Wastewater

INTENDED ACTION:

The Alabama Plumbers and Gas Fitters Examining Board proposes to add rule 720x-x2-.02 of Alabama Code 34-37

SUBSTANCE OF PROPOSED ACTION:

The proposed action of rule 720-x-2.02 would clarify section 34-37-1(11) responsibility of on-site wastewater disposal systems.

TIME, PLACE, MANNER OF PRESENTING VIEWS:

Comments may be submitted in writing or orally at a public hearing to be held at 4:00 p.m., January 14, 2016, in the Board's office located at 11 West Oxmoor Road, Suite 104, Birmingham, AL 35209. Comments will be accepted until 4:30 p.m. on February 4, 2016.

FINAL DATE FOR COMMENT AND COMPLETION OF NOTICE:

February 4, 2016

CONTACT PERSON AT AGENCY:

David H. Wilcox (205) 945-4857



David H. Wilcox
Executive Director

State of Alabama Plumbers and Gas Fitters Examining Board

New Rule

720-x-2-.02

720-x-2-.02 Onsite Wastewater. On-site wastewater disposal systems which are represented by drawings signed and sealed by an engineer licensed in the State of Alabama shall not be considered plumbing. Any other onsite system installed by any legal entity holding a current license with the Alabama Onsite Wastewater Board shall not be considered plumbing to within 3 to 5 feet of the building or residence.

Author: David H. Wilcox

Statutory Authority: Section 34-37-2 (Code of Alabama 1975 as amended)

History: New Rule

Certified: