

APA-2
11/96

DEPARTMENT OF ENVIRONMENTAL MANAGEMENT
WATER DIVISION

NOTICE OF INTENDED ACTION

AGENCY NAME: DEPARTMENT OF ENVIRONMENTAL MANAGEMENT

RULE NO. & TITLE: 335-7-5-.13 Springs (Amend)
335-7-5-.15 Ground Water Quality (Amend)
335-7-5-.17 Disinfection Requirements (Amend)
335-7-5-.18 Filtration Requirements (Amend)
335-7-5-.22 Ground Water Rule (Amend)

INTENDED ACTION: The Alabama Department of Environmental Management proposes to revise division 335-7, Public Water Supply.

SUBSTANCE OR PROPOSED ACTION: Revisions to rules 335-7-5-.13(b) 335-7-5-.15 (b), 335-7-5-.17 (a) 3, and 335-7-5-.18, 335-7-5-.22 (5)(a) 1. (ii) and 335-7-5-.22(6)(b) 3. (i) (l) are being proposed to make administrative changes and to clarify requirements.

TIME, PLACE, MANNER OF PRESENTING VIEWS: Comments may be submitted in writing or orally at a public hearing to be held May 2, 2012, at 10:00 a.m. in the Main Hearing Room at the ADEM Central Office located at 1400 Coliseum Blvd., Montgomery, AL 36110.

FINAL DATE FOR COMMENT AND COMPLETION OF NOTICE: May 4, 2012 at 5:00 p.m.

CONTACT PERSON AT AGENCY: George M. Cox, Section Chief
Groundwater Section [334/271-7778]



Lance R. LeFleur
Director

335-7-5-.18 Filtration Requirements. Treatment processes to include filtration are required when raw water quality from a groundwater source exceeds any of the following parameters:

- (a) Turbidity - 5.0 NTU
- (b) Total Coliform - 100 per 100 milliliter of sample
- (c) Fecal Coliform (or E. coli) - 20 per 100 milliliter of sample
- (d) Iron - 0.6 milligrams per liter
- (e) Manganese - 0.1 milligrams per liter

Author: Joe Alan Power, Edgar K. Hughes.

Statutory Authority: Code of Alabama 1975, §§ 22-23-1 through 22-24-12.

History: May 23, 1977; Repealed and readopted: January 4, 1989; October 31, 1990.

Amended: December 8, 1998; effective: January 25, 1999; June 7, 2000; December 12, 2005; XXXXX, 2012.