

APA-2
11/96

DEPARTMENT OF ENVIRONMENTAL MANAGEMENT
WATER DIVISION

NOTICE OF INTENDED ACTION

AGENCY NAME: DEPARTMENT OF ENVIRONMENTAL MANAGEMENT

RULE NO. & TITLE: 335-6-15-.02 Definitions (Amend)


INTENDED ACTION: The Alabama Department of Environmental Management proposes to amend Administrative Code Rule 335-6-15-.02.

SUBSTANCE OR PROPOSED ACTION: A revision is being proposed to the definition of "Cathodic Protection Tester" in this rule to allow a certified cathodic protection tester 90 days to become recertified after the cathodic protection tester's certification expires. Also, a revision is being proposed to the definition of "Routine Maintenance" to remove the repair or replacement of shear valves from the definition, and also to clarify that routine maintenance does not include work that involves breaking ground or paved surfaces.

TIME, PLACE, MANNER OF PRESENTING VIEWS: Comments may be submitted in writing or orally at a public hearing to be held at 1:00 p.m., January 9, 2014, in the ADEM Main Hearing Room, 1400 Coliseum Boulevard, Montgomery, Alabama 36110.

FINAL DATE FOR COMMENT AND COMPLETION OF NOTICE: January 9, 2014

CONTACT PERSON AT AGENCY: Sonja Massey (334) 271-7832



Lance R. LeFleur
Director