

APA-2
11/96

**DEPARTMENT OF ENVIRONMENTAL MANAGEMENT
WATER DIVISION**

NOTICE OF INTENDED ACTION

AGENCY NAME: DEPARTMENT OF ENVIRONMENTAL MANAGEMENT

RULE NO. & TITLE: 335-6-15-.15 Release Detection Requirements for Petroleum UST Systems (Amend)


INTENDED ACTION: The Alabama Department of Environmental Management proposes to amend Administrative Code Rule 335-6-15-.15.

SUBSTANCE OR PROPOSED ACTION: A revision is being proposed to this rule to allow tanks up to a nominal 1000 gallon capacity to use weekly tank gauging as a stand-alone method of leak detection. Also, revisions are being proposed to this rule to clarify that piping interstitial monitoring must be performed monthly, and to clarify the last installation date where other piping leak detection options are allowed.

TIME, PLACE, MANNER OF PRESENTING VIEWS: Comments may be submitted in writing or orally at a public hearing to be held at 1:00 p.m., January 9, 2014, in the ADEM Main Hearing Room, 1400 Coliseum Boulevard, Montgomery, Alabama 36110.

FINAL DATE FOR COMMENT AND COMPLETION OF NOTICE: January 9, 2014

CONTACT PERSON AT AGENCY: Sonja Massey (334) 271-7832



Lance R. LeFleur
Director