

APA-2  
11/96

**DEPARTMENT OF ENVIRONMENTAL MANAGEMENT  
WATER DIVISION**

**NOTICE OF INTENDED ACTION**

**AGENCY NAME:** DEPARTMENT OF ENVIRONMENTAL MANAGEMENT

**RULE NO. & TITLE:** 335-6-15-.17 Methods of Release Detection for Tanks (Amend)


**INTENDED ACTION:** The Alabama Department of Environmental Management proposes to amend Administrative Code Rule 335-6-15-.17.

**SUBSTANCE OR PROPOSED ACTION:** A revision is being proposed to this rule to no longer allow tanks greater than a nominal 1000 gallon capacity to use weekly tank gauging combined with tank tightness testing as a method of leak detection. Also, revisions are being proposed to this rule to clarify Department approval requirements for other leak detection methods not specified in this rule.

**TIME, PLACE, MANNER OF PRESENTING VIEWS:** Comments may be submitted in writing or orally at a public hearing to be held at 1:00 p.m., January 9, 2014, in the ADEM Main Hearing Room, 1400 Coliseum Boulevard, Montgomery, Alabama 36110.

**FINAL DATE FOR COMMENT AND COMPLETION OF NOTICE:** January 9, 2014

**CONTACT PERSON AT AGENCY:** Sonja Massey (334) 271-7832

  
\_\_\_\_\_  
Lance R. LeFleur  
Director